

TECHNICAL ACT OF 1 JULY 2004

305 VP 10/8 compressor: less power and noise, higher output

OJSC Poltava Auto Aggregate Plant (PAAZ), main compressor station · approved by: chief power engineer A. K. Cherednyk

Poltava, Ukraine · works 02.04–01.07.2004 · act of 01.07.2004

PRODUCT

XADO revitalizant gel
formulation for compressors
and bearings

TEST OBJECT

305 VP 10/8 piston
compressor
two-stage, inv. No. 18860 ·
driven by an electric motor

**RUNNING TIME AFTER
TREATMENT**

215 hours
control measurements after
three months in service

UNIT

305 VP 10/8 piston compressor,
inv. No. 18860 — stages I and II
with the drive electric motor

**RUNNING TIME AT
CONTROL
MEASUREMENTS**

215 h over the period
02.04–01.07.2004

WHAT WAS MEASURED

Current and power on three phases,
vibration at 5 points, noise at 2 points,
receiver filling time

The baseline and control measurements were taken in identical modes: idle at 1 kgf/cm² and under load at 6 kgf/cm².

Key results

↓ **8.1%**

power draw under 6 kgf/cm² load, by
phase 58.5–61 → 54–57 kW

↓ **3.5–10.3%**

current draw by phase under 6 kgf/cm²
load, 114–117 → 105–110 A

↑ **2.7 %**

output, receiver filling 0-7 kgf/cm², 3 min
44 s → 3 min 38 s

↓ **6.5-7.5 dB**

noise level at two points, 87.5-89.5 →
80-83 dB

Electricity consumption — current and power by phase

PARAMETER	MODE	BEFORE TREATMENT	AFTER 215 H
Current on phases A / B / C, A	under load, 6 kgf/cm ²	114 / 117 / 117	110 / 105 / 109
Current on phases A / B / C, A	idle, 1 kgf/cm ²	76 / 77 / 79	77 / 73 / 77
Power on phases A / B / C, kW	under load, 6 kgf/cm ²	60 / 58.5 / 61	57 / 54 / 54
Power on phases A / B / C, kW	idle, 1 kgf/cm ²	29.3 / 26.5 / 29	25 / 25 / 26
Mains voltage, V	both modes	390	392

The mains voltage was virtually unchanged at the control measurement — the drop in power draw is not explained by a supply sag.

Vibration at five control points

MEASUREMENT POINT	SPECTRUM ENVELOPE	VIBRATION VELOCITY, mm/s	VIBRATION DISPLACEMENT, μm
P.1 — frame	0.396 → 0.813	1.67 → 1.67	36.2 → 38.3
P.2 — stage I, lateral	5.18 → 5.97	3.15 → 3.1	107 → 106
P.3 — stage II, lateral	7.21 → 10.9	3.25 → 3.22	99.4 → 97.2
P.4 — stage II, axial	1.74 → 3.8	4.11 → 4.08	134 → 131
P.5 — stage I, axial	4.1 → 4.78	6.59 → 6.2	191 → 191

The spectrum envelope is read as stated in the act: the larger it is, the lower the vibration level — this is what the commission used to derive the 13.2-54.2% reduction.

Output and noise level

PARAMETER	POINT / MODE	BEFORE TREATMENT	AFTER 215 H
Receiver filling time	from 0 to 7 kgf/cm ²	3 min 44 s	3 min 38 s
Receiver filling time	from 4 to 7 kgf/cm ²	1 min 38 s	1 min 38 s
Noise level	point 1 — motor side	89.5 dB	83 dB
Noise level	point 2 — control panel side	87.5 dB	80 dB

The filling time of the standard receiver is a direct measure of compressor delivery: the shorter the time, the higher the output.

Finding of the OJSC PAAZ commission

The commission of OJSC PAAZ recorded in the act: "The results of the final measurements of the compressor's operating parameters compared with the initial parameters show that, after the application of XADO revitalizants, the average power draw in idle mode decreased by **10.2%**, while in load mode the power draw decreased by **8.1%**. The vibration level at the control points decreased by **13.2%** to **54.2%** (a larger spectrum envelope means a lower vibration level). The compressor noise level at the control points decreased by **6.5 dB** to **7.5 dB**. The compressor output when filling the receiver from 0 atm to 7 atm increased by **2.7%**. According to the operating personnel, oil consumption from the crankcase and through the lubricator decreased, and the noisiness of the compressor's operation was noticeably reduced. The analysis carried out demonstrates the effectiveness of applying XADO technology for the purpose of saving electricity, restoring worn parts and extending the service life of the compressor."

XADO

© XADO. All rights reserved.

The results apply to the 305 VP 10/8 piston compressor of the main compressor station of OJSC PAAZ and to 215 hours of running time after treatment; on other units and in other modes the figures may differ. The measurements were taken jointly by plant specialists and representatives of JV AVIS and XADO LLC; the act was approved by the plant's chief power engineer. The original act is published in full and available for download.